Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No:	AL0058408			
Monitoring Period				
From: 6/1/2025	To: 6/30/2025			

Digitally signed by: AEPACS Date: 2025.07.28 19:42:58 -05:00 Reason: Copy Of Record Location: State of Alabama

Outfall: 001-1

Parameter		Quantity (or Loading	Units	Qual	lity or Concentr	ration	Units	No. Ex.	Sample Freq	Sample Type
Turbidity (00070)	Sample Measurement	****	****	****	****	1.43	2.89	NTU	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		U	5X Weekly	Grab
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	****	7.35	****	****		0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****	mg/l		3X Weekly test	Grab
pH (00400)	Sample Measurement	1 ******	****	_ *****	6.81	****	7.59	S.U.	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	9.0 Maximum Daily		U	3X Weekly test	Grab
Solids, Total Suspended	Sample Measurement	300	383		****	6.3	7.7	- mg/l	0	3X Weekly test	24-Hr Composite
(00530) EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average		U	3X Weekly test	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	07/28/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: 6/1/2025	To: 6/30/2025				

Parameter		Quantity (or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Solids, Total Suspended (00530)	Sample Measurement	5482	7435	lbs/day	****	120	172	- mg/l	_	3X Weekly test	24-Hr Composite	
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	105/day	****	REPORT Monthly Average	REPORT Weekly Average		0	3X Weekly test	24-Hr Composite	
Nitrogen, Ammonia Total (As N) (00610)	Sample Measurement	11.27	27.78	lbs/day	****	0.23	0.53	mg/l			3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	37.5 Monthly Average	56.2 Weekly Average	los/day	****	1.0 Monthly Average	1.5 Weekly Average		0	3X Weekly test	24-Hr Composite	
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	28	28	11 /1	****	0.62	0.62		0	Monthly	24-Hr Composite	
(00625) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l		Monthly	24-Hr Composite	
Nitrite Plus Nitrate Total 1 Det. (As N) (00630) EFFLUENT GROSS VALUE	Sample Measurement	89	89		****	2.00	2.00			Monthly	24-Hr Composite	
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite	

NAME OF PRINCIPAL I	
OFFICER OR AUTHORI	ZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 831-5618	07/28/2025		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From:	To:				
6/1/2025	6/30/2025				

Parameter		Quantity (or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Phosphorus, Total (As P)	Sample Measurement	8	8	lbs/day	****	0.19	0.19	- mg/l	0	Monthly	24-Hr Composite
(00665) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	ios/day	****	REPORT Monthly Average	REPORT Weekly Average		0	Monthly	24-Hr Composite
Silver Total Recoverable (01079)	Sample Measurement	****	****	****	****	*B	*B	· ug/l	0	Monthly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily			Monthly	Grab
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	44	ADMI	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	****	80 Maximum Daily			5X Weekly	Grab
Flow, In Conduit or Thru	Sample Measurement	5.67	9.46	MGD	****	****	*****	****		Daily	Continuous
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****	_ ****	0	Daily	Continuous

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 831-5618	07/28/2025		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408				
Monitoring Period				
From: 6/1/2025	To: 6/30/2025			

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Chlorine, Total Residual	Sample Measurement	****	****	****	****	*9	*9	mg/l	0	3X Weekly test	Grab
(50060) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily			3X Weekly test	Grab
E. Coli (51040)	Sample Measurement	****	****	****	****	39	83	col/100mL 0 -	5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	126 Monthly Average	298 Maximum Daily		0	5X Weekly	Grab
Cyanide, Free Available	Sample Measurement	****	***** *B	*B	*B			Monthly	Grab		
(51173) EFFLUENT GROSS VALUE	Permit Requirement	****	****	****	****	31.4 Monthly Average	70.5 Maximum Daily	ug/l	0	Monthly	Grab
Peracetic Acid (51674)	Sample Measurement	****	****	****	****	****	0.19	(1	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE	
Electronically Signed via AEPACS	(256) 831-5618	07/28/2025	

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408				
Monitoring Period				
From: 6/1/2025	To: 6/30/2025			

Parameter		Quantity (or Loading	Units	Qual	ity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	185	220		****	3.9	4.2	a	0	3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	300 Monthly Average	450 Weekly Average	lbs/day	****	8.0 Monthly Average	12.0 Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	2352	2721	lho/dov	****	51	59	m c /l	0	3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l		3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C,	Sample Measurement	****	****	****	92	****	****	%	0	Monthly	Calculated
Percent Remvl (80091) Percent Removal	Permit Requirement	****	****	*****	85.0 Monthly Average Minimum	****	****			Monthly	Calculated
Solids, Suspended Percent	Sample Measurement	****	****	****	94	****	****			Monthly	Calculated
Removal (81011) Percent Removal	Permit Requirement	****	****	*****	85.0 Monthly Average Minimum	****	****	%	0	Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE	
Electronically Signed via AEPACS	(256) 831-5618	07/28/2025	

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP

Location: 2975 Silver Run Road Oxford, AL 36203

County: Talladega

Permit No: AL0058408

Monitoring Period

From: To: 6/1/2025 6/30/2025

END OF REPORT

NAME OF PR	INCIPAL	EXEC	CUTIVE
OFFICER OR	AUTHOR	IZED	ACENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE	
Electronically Signed via AEPACS	(256) 831-5618	07/28/2025	

Submission Identifier: DMR-AL0058408-20250630-1

Submission Signature Hash: Rmr3nOvKdGaz3Tj/INBj4MCI7AQrQpBnSt7N4gKDRBY=

Submitter Name: Meredith Holzer

Submitter Email: mholzer@oxfordwater.com

Submitted Date/Time: 7/28/2025 7:42:58 PM