Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP
Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

AL0058408							
Monitoring Period							
To:							
10/31/2025							

Digitally signed by: AEPACS Date: 2025.11.28 13:00:12 -06:00 Reason: Copy Of Record Location: State of Alabama

#### Outfall: 001-1

Parameter		Quantity o	or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Turbidity (00070)	Sample Measurement	****	****	****	****	2.20	3.28	NTU	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		U	5X Weekly	Grab
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	****	6.82	****	*****	mg/l	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****			3X Weekly test	Grab
pH (00400)	Sample Measurement	****	****	****	7.26	****	7.70	- S.U.	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	9.0 Maximum Daily			3X Weekly test	Grab
Solids, Total Suspended	Sample Measurement	290	411	lha/day	****	16.3	25.7	- mg/l		3X Weekly test	24-Hr Composite
(00530) EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average		0	3X Weekly test	24-Hr Composite

	F PRINCIPAL EXECUTIVE
OFFICE	R OR AUTHORIZED AGENT

Meredith Holzer

r 1	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE			
t r	Electronically Signed via AEPACS	(256) 831-5618	11/28/2025			

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

**Outfall: 001-1** 

Permit No: AL0058408									
Monitoring Period									
From: 10/1/2025	<b>To:</b> 10/31/2025								

Parameter	Quantity or Loading		Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Solids, Total Suspended (00530)	Sample Measurement	4262	10422	lbs/day	****	229	500	mg/l		3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	los/day	****	REPORT Monthly Average	REPORT Weekly Average		0	3X Weekly test	24-Hr Composite
Nitrogen, Ammonia Total (As	Sample Measurement	8.49	20.58	lbs/day -	****	0.44	0.97	mg/l	0	3X Weekly test	24-Hr Composite
N) (00610) EFFLUENT GROSS VALUE	Permit Requirement	37.5 Monthly Average	56.2 Weekly Average		****	1.0 Monthly Average	1.5 Weekly Average			3X Weekly test	24-Hr Composite
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	287	287	· lbs/day -	****	18.30	18.30	mg/l	0	Monthly	24-Hr Composite
(00625) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			Monthly	24-Hr Composite
Nitrite Plus Nitrate Total 1 Det.	Sample Measurement	4	4	11/4	****	0.27	0.27		0	Monthly	24-Hr Composite
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l		Monthly	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system,	AUTHORIZED ACENT	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 831-5618	11/28/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

**Facility Name:** Oxford Tull C. Allen WWTP **Location:** 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

**Outfall: 001-1** 

Permit No: AL0058408

Monitoring Period

From: To: 10/1/2025 10/31/2025

Parameter		Quantity (	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Phosphorus, Total (As P) (00665)	Sample Measurement	20	20	lho/dov	****	1.30	1.30	mg/l		Monthly	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average		0	Monthly	24-Hr Composite
Silver Total Recoverable	Sample Measurement	****	****	****	****	*B	*B	ug/l - ADMI	0	Monthly	Grab
(01079) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily			Monthly	Grab
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	78			5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	80 Maximum Daily			5X Weekly	Grab
Flow, In Conduit or Thru	Sample Measurement	2.13	2.79	MGD	****	****	****	****		Daily	Continuous
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****	- ****	0	Daily	Continuous

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	11/28/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

**Outfall: 001-1** 

Permit No:	AL0058408						
Monitoring Period							
<b>From:</b> 10/1/2025	<b>To:</b> 10/31/2025						

Parameter		Quantity of	r Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Chlorine, Total Residual (50060)	Sample Measurement	****	****	****	****	*9	*9			3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily	mg/l	0	3X Weekly test	Grab
E. Coli (51040)	Sample Measurement	****	****	****	****	21	89	- col/100mL	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	****	****	126 Monthly Average	298 Maximum Daily			5X Weekly	Grab
Cyanide, Free Available	Sample Measurement	****	****	****	****	*B	*B	- ug/l	0	Monthly	Grab
(51173) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily			Monthly	Grab
Peracetic Acid (51674)	Sample Measurement	****	****	****	****	****	0.88		0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab

NAME OF PRINCIPAL I	
OFFICER OR AUTHORI	ZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	11/28/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

**Outfall: 001-1** 

Permit No: AL0058408				
Monitoring Period				
<b>From:</b> 10/1/2025	<b>To:</b> 10/31/2025			

Parameter		Quantity (	or Loading	Units	Qual	ity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	90	115	- lbs/day	****	5.1	7.1	4		3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	300 Monthly Average	450 Weekly Average		****	8.0 Monthly Average	12.0 Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	1525	1664		****	88	109	mg/l		3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average		0	3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C,	Sample Measurement	****	****	****	94	****	****	- %		Monthly	Calculated
Percent Remvl (80091) Percent Removal	Permit Requirement	****	****	*****	85.0 Monthly Average Minimum	****	****		90	0	Monthly
Solids, Suspended Percent	Sample Measurement	****	****	****	90	****	****	%	0	Monthly	Calculated
Removal (81011) Percent Removal	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****	70		Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	11/28/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408

Monitoring Period

From: To: 10/1/2025 10/31/2025

END OF REPORT

NAME OF PR	INCIPAL	EXEC	UTIVE
OFFICER OR	AUTHOR	IZED	ACENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	11/28/2025

**Submission Identifier:** DMR-AL0058408-20251031-1

**Submission Signature Hash:** aq8fcWTFFXGj6lWYkbJYD7JYE4UFPMbCweQzyjw8zHM=

**Submitter Name:** Meredith Holzer

**Submitter Email:** mholzer@oxfordwater.com

**Submitted Date/Time:** 11/28/2025 1:00:11 PM