Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP
Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408					
Monitoring Period					
From: 4/1/2025	To: 4/30/2025				

Digitally signed by:
AEPACS
Date: 2025.05.27 14:55:17 -05:00
Reason: Copy Of Record
Location: State of Alabama

Outfall: 001-1

Parameter		Quantity of	or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Turbidity (00070)	Sample Measurement	****	****	*****	****	2.98	4.83	NITLI	0	5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily	NTU	U	5X Weekly	Grab	
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	*****	7.00	****	****	mg/l	0	3X Weekly test	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****			3X Weekly test	Grab	
рН (00400)	Sample Measurement	****	****	****	6.0 Minimum Daily	6.88	****	7.21	S.U.		3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****			****	9.0 Maximum Daily	S.U.	0	3X Weekly test	Grab	
Solids, Total Suspended	Sample Measurement	395	764			****	8.3	11.8	/1		3X Weekly test	24-Hr Composite
(00530) EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average	mg/l 0	U	3X Weekly test	24-Hr Composite	

	PRINCIPAL EXECUTIVE
OFFICER O	OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	05/27/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From:	To:				
4/1/2025	4/30/2025				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Solids, Total Suspended	Sample Measurement	6495	10963	- lbs/day -		****	137	180	ma/1	0	3X Weekly test	24-Hr Composite
(00530) RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average	mg/l	U	3X Weekly test	24-Hr Composite	
Nitrogen, Ammonia Total (As N) (00610)	Sample Measurement	205.82	303.25	- lbs/day	****	4.28	4.49	mg/l		3X Weekly test	24-Hr Composite	
EFFLUENT GROSS VALUE	Permit Requirement	750 Monthly Average	1125 Weekly Average		****	20.0 Monthly Average	30.0 Weekly Average		0	3X Weekly test	24-Hr Composite	
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	15	15	lbs/day		****	0.63	0.63	4		Monthly	24-Hr Composite
(00625) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average			****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite
Nitrite Plus Nitrate Total 1 Det.			****	3.10	3.10	(1		Monthly	24-Hr Composite			
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite	

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	AUTHORIZED AGENT	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 831-5618	05/27/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: 4/1/2025	To: 4/30/2025				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type		
Phosphorus, Total (As P) (00665)	Sample Measurement	3	3	lbs/day -			****	0.12	0.12	ma/1	0	Monthly	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average	mg/l	U	Monthly	24-Hr Composite		
Silver Total Recoverable (01079)	Sample Measurement	****	****	****	****	*B	*B	ug/l	0	Monthly	Grab		
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily			Monthly	Grab		
Color (ADMI Units) (01290)	Sample Measurement	****	****	*****	****	****	****	46	4 DV (I		5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****			****	****	80 Maximum Daily	ADMI	0	5X Weekly	Grab	
Flow, In Conduit or Thru Treatment Plant (50050)	Sample Measurement	5.72	9.98	Map		****	****	****	****	0	Daily	Continuous	
EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****	****	0	Daily	Continuous		

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	05/27/2025

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: 4/1/2025	To: 4/30/2025				

Parameter		Quantity of	r Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Chlorine, Total Residual	Sample Measurement	****	****	****	****	*9	*9			3X Weekly test	Grab
(50060) EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	0.066 Monthly Average	0.115 Maximum Daily	mg/l	0	3X Weekly test	Grab
E. Coli (51040)	Sample Measurement	****	****	****	****	37	100	col/100mL	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	548 Monthly Average	2507 Maximum Daily	col/100mL	U	5X Weekly	Grab
Cyanide, Free Available	Sample Measurement	****	****	****	****	*B	*B			Monthly	Grab
(51173) EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	31.4 Monthly Average	1.4 70.5 Average Maximum Daily	ug/I	0	Monthly	Grab
Peracetic Acid (51674)	Sample Measurement	****	****	****	****	****	0.16		0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	****	1.0 Maximum Daily	mg/l		5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 831-5618	05/27/2025		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: 4/1/2025	To: 4/30/2025				

Parameter		Quantity (or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	214	294	lbs/day	****	4.5	5.4	ma (/I	0	3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	938 Monthly Average	1407 Weekly Average	ios/day	****	25.0 Monthly Average	37.5 Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day,	Sample Measurement	2674	3858	11/-1	****	58	63		0	3X Weekly test	24-Hr Composite
20C (80082) RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l		3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C,	Sample Measurement	****	****	****	92	****	****	%	0	Monthly	Calculated
Percent Remvl (80091) Percent Removal	Permit Requirement	****	****	*****	85.0 Monthly Average Minimum	****	****			Monthly	Calculated
Solids, Suspended Percent	Sample Measurement	****	****	****	91	****	****	%		Monthly	Calculated
Removal (81011) Percent Removal	Permit Requirement	****	****	40.40.40.40	85.0 Monthly Average Minimum	****	****		0	Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 831-5618	05/27/2025		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408

Monitoring Period

From: To: 4/1/2025 4/30/2025

END OF REPORT

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 831-5618	05/27/2025		

Submission Identifier: DMR-AL0058408-20250430-1

Submission Signature Hash: d7rV8mb5EoKT0dDszXYG2a50hnUhPMoSwJJCihDVaFU=

Submitter Name: Meredith Holzer

Submitter Email: mholzer@oxfordwater.com

Submitted Date/Time: 5/27/2025 2:55:16 PM